

City of Plainview

2010 Suggested Usage Schedule from CRMWA

	LAKE		WELLS		TOTAL		Peak Day Demand MGD	Estimated Blend		Water Quality	
	Schedule Monthly (k-Gal)	Actual To-Date (k-Gal)	Schedule Monthly (k-Gal)	Actual To-Date (k-Gal)	Schedule Monthly (k-Gal)	Actual To-Date (k-Gal)		Lake %	Wells %	Cl's ppm	TDS ppm
<i>Allocation</i>	3.691%		3.691%		3.691%						
January	14,907	3	34,508	3	49,416	6	5.4	30 %	70 %	264	866
February	17,298	-	41,292	-	58,590	-	5.4	30 %	70 %	260	856
March	28,590	6,391	51,615	8,748	80,205	15,139	5.8	36 %	64 %	299	955
April	30,147	18,346	41,292	16,049	71,440	34,395	6.5	42 %	58 %	341	1,061
May	33,975	37,220	74,925	37,361	108,900	74,581	8.9	31 %	69 %	271	883
June	29,868	-	59,940	-	89,808	-	9.6	33 %	67 %	284	916
July	38,561	-	59,940	-	98,502	-	10.2	39 %	61 %	322	1,011
August	45,226	-	74,925	-	120,151	-	10.8	38 %	62 %	312	987
September	24,302	-	59,940	-	84,242	-	8.8	29 %	71 %	255	845
October	12,363	-	53,344	-	65,707	-	6.3	19 %	81 %	191	682
November	14,338	-	61,864	-	76,202	-	5.5	19 %	81 %	191	682
December	11,103	-	47,907	-	59,010	-	5.5	19 %	81 %	191	682
Schedule-To-Date	124,917	61,960	243,633	62,161	368,550	124,121					
Yearly Total	300,679		661,494		962,173						
Yearly Total (Acre-Feet)	923		2,030		2,953			31%	69%		

Notes:

1. Contract Delivery Rate (MGD) = 4.15
2. The Yearly Total from the above Usage Schedule is the City's allocation. Monthly Usage Schedule is estimated using CRMWA billing months in which meters are read the last Monday of each month (except last reading - Dec 29th, 2010).
3. Water quality is based on the current conditions of Lake Meredith and John C. Williams Wellfield.